



Commercial Downlight Emergency Back-Up Installation Instructions

EMBACKUPCOMDL1
EMBACKUPCOMDL2

IMPORTANT: Must be installed by a Qualified Electrician.

Please read instructions before proceeding with installation. Keep these instructions for future reference.

WARNING

RISK OF ELECTRIC SHOCK

- Turn off power prior to inspection, installation or removal of fixture.
- Ensure electrical enclosure is properly grounded in accordance with National Electrical Code (NEC) and/or Canadian Electrical Code (CSA).

RISK OF FIRE

- CAUTION - RISK OF FIRE
- Product must be installed in accordance with NEC and/or applicable local codes by a qualified licensed electrician.
- Wiring connections should be made with UL approved wire connectors.

Installation instructions:

- Surface mounting and suspending mounting are acceptable.
- For use in damp or dry locations only.
- This item could be used in the sealed fixtures or installed in the open area of the fixtures.
- Do not expose the product to fire or excessive temperature. Any such exposure to fire or temperature above the ratings may cause explosion.
- Do not disassemble the product. This product has no serviceable parts.
- Charge the battery consistently for >24 hours for the first time usage to activate the whole battery cell discharging/charging cycles.

THIS PRODUCT MUST BE INSTALLED IN ACCORDANCE WITH THE APPLICABLE INSTALLATION CODE BY A PERSON FAMILIAR WITH THE CONSTRUCTION AND OPERATION OF THE PRODUCT AND THE HAZARDS INVOLVED.

continued on back

These instructions are not intended to cover all details or variations in your equipment or your particular requirements for installation, operation or maintenance. Should further information on this product be needed that is not covered by these general installation instructions, please contact the TCP Customer Service Department at phone number 800-324-1496 for further assistance.

SAVE THESE INSTRUCTIONS

TCP®

325 Campus Dr. | Aurora, Ohio 44202 | P: 800-324-1496 | tcp.com


READ AND FOLLOW ALL SAFETY INSTRUCTIONS

ATTENTION

- Do not disassemble fixture. No user or serviceable parts inside.
- Do not use this equipment for other than its intended use.

ELECTRICAL CONNECTION

Wiring diagram



These instructions are not intended to cover all details or variations in your equipment or your particular requirements for installation, operation or maintenance. Should further information on this product be needed that is not covered by these general installation instructions, please contact the TCP Customer Service Department at phone number 800-324-1496 for further assistance.

SAVE THESE INSTRUCTIONS

TCP®

325 Campus Dr. | Aurora, Ohio 44202 | P: 800-324-1496 | tcp.com

©TCP JULY 2021/WF272350